

## **Declaration of Performance**

## DoP-PSC-1000

Unique identification code of the product-type	PSC-1000
Type, batch or serial number of the construction product	PSC-1000
Intended use	Fire Safety Powersupply
Name and contact address of the manufacturer	TMCDAS B.V. Newtonstraat 18 1704 SB Heerhugowaard
Name and contact address of the authorized representative	Not applicable
System of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V	System 1
Activity of the Notified Certification body as required by the harmonized standard The notified body	CNBOP-PIB
With the identification number	1438
Performed the following tasks under system 1:	1430
<ul> <li>I. Determination of the product type on the basis of type testing, type calculation, tabulated values or descriptive documentation of the product</li> <li>II. Initial inspection of the manufacturing plant and of factory production control</li> <li>III. Continuous surveillance, assessment and evaluation of factory production control</li> </ul>	
And issued the EC Certificate of	EC Certificate of Conformity
Conformity	1438/CPR/0570
	Type, batch or serial number of the construction product Intended use  Name and contact address of the manufacturer  Name and contact address of the authorized representative  System of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V  Activity of the Notified  Certification body as required by the harmonized standard  The notified body  With the identification number  Performed the following tasks under system 1:  I. Determination of the product type on the basis of type testing, type calculation, tabulated values or descriptive documentation of the product  II. Initial inspection of the manufacturing plant and of factory production control  III. Continuous surveillance, assessment and evaluation of factory production



## 9. Declared Performance

Performance Harmonized technical specification **Essential characteristics** Performance under fire condition Compliant EN54-4: 1997/A1:2003 + A2: 2006 Section: 4, 5, 6 Operational reliability Compliant EN54-4: 1997/A2: 2006 Section: 4, 5, 6, 7, 8 Durability of operational reliability: Compliant EN54-4: 1997/A2: 2006 Section: 9.5 temperature resistance Durability of operational reliability: Compliant EN54-4: 1997/A2: 2006 vibration resistance Section: 9.7, 9.8, 9.15 Durability of operational reliability: Compliant EN54-4: 1997/A2: 2006 Section: 9.9 electrical stability Durability of operational reliability: Compliant EN54-4: 1997/A2: 2006 Section: 9.6, 9.14 humidity resistance

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signature

Signed for and on behalf of the manufacturer by:

L.G. Slippens, Managing Director

Name and function

Heerhugowaard, 21-11-2017

Place and date of issue